

CITY OF BLOOMFIELD
INVITATION TO BID # 2020-01
ADDENDUM NO. 1

Issued: October 1, 2019

The following clarifications are made related to the above-referenced ITB:

1. Generator size shall be 400 kW Name Plate Rating.
2. Questions on the ITB will be accepted until Thursday October 10, 2020 at 2:00 pm (one week before the Bids are due).
3. Annunciator Panel shall be placed in the Operator Control Office.

Bidders MUST acknowledge receipt of this Addendum on the Bid Form, Page 25 of the Invitation to Bid.



Brad Ellsworth, Finance Director